



Product Evaluation

WIN2188 | 0317

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2188

Effective Date: March 1, 2017

Re-evaluation Date: March 2019

Product Name: Aluminum Clad Wood StormForce Single Hung Window, Fin/Frame Installation, Impact Resistant

Manufacturer: Loewen Windows
77 Highway 52 West
Steinbach, Manitoba
Canada R5G 182
800-563-9367

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Aluminum Clad Wood StormForce Single Hung Window	LC-PG55 45 x 100 - H Missile Level D	+55 / -55 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Glass Daylight Opening Size
1	45-13/16" x 100"	42-5/8" x 50-3/8"	39-1/16" x 44-15/16"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Loewen
	Product Name	Single Hung Window StormForce
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E 1886-05; ASTM E 1996-05; Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris in the Inland I and Seaward zone. Install the assemblies at a height on the structure that does not exceed the assemblies' design pressure rating.

Installation:

System		
1	Type of Installation	Fin / Frame Installation
	Wall Framing	Southern Yellow Pine dimension lumber
	Fasteners	Fin: 2" long 11-gauge smooth shank roofing nails Frame: No. 10 x 3" wood screws
	Fastener Location/Spacing	Secure the nailing fin to the wall framing with the roofing nails spaced approximately 3" from each corner and approximately 6" on center along the perimeter. Secure the side jambs to the wall framing with the screws through the interior sash stops spaced 4", 16", 24", 54", and 60" from the bottom of the frame.
	Fastener Penetration	Minimum 1-1/2" penetration into wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.